



# Thomas & Betts

## ANALYSIS OF NEC ®

2017 Code Changes: Article Section 409.22(B) Documentation  
Section 409.22(B) Documentation

**Thomas&Betts**  
A Member of the ABB Group

© 2017 Thomas & Betts. Specifications are subject to change without notice.

# Section 409.22(B) Documentation

## Section 409.22(B) Documentation

**(B) Documentation.** If an industrial control panel is required to be marked with a short-circuit current rating in accordance with 409.110(4). The available short circuit current at the industrial control panel and the date the short circuit current calculation was performed shall be documented and made available to those authorized to inspect the installation.

## Analysis of the Change

New section 409.22(B) was included to require a field marking requirement for industrial control panels to indicate the available short-circuit current at the industrial control panel and the date the short circuit calculation was performed. This information shall be documented and made available to the AHJ. This is similar to the available fault-current field marking requirements of 110.24(A).

## Products

ABB Enclosed Switches, T&B Conduit and Voltage Marker Cards – Vinyl, T&B Safety Labels, ABB Switchgear



# Contact Us

If you have any questions or require interpretation assistance, please contact the following:

David Kendall ..... 1-800-888-0211 Ext. 8879

Greg Steinman ..... 1-800-888-0211 Ext. 5719

Jean Blanc ..... 1-800-888-0211 Ext. 5670

Thomas & Betts Corporation

8155 T&B Blvd.

Memphis, TN 38125

[www.tnb.com](http://www.tnb.com)

Disclaimer: This is not intended to be an iteration of all the changes, but a reference of a change that may affect the Thomas & Betts, ABB & Baldor product lines. For a more in-depth document, please contact the International Association of Electrical Inspectors at [www.iaei.org](http://www.iaei.org).

Material taken from the National Electrical Code is reprinted with permission from NFPA 70®-2017, National Electrical Code®, Copyright © 2016, National Fire Protection Association, Quincy, MA. This material is not the official position of the NFPA on the referenced subject, which is represented only by the standard in its entirety.

National Electrical Code® and NEC® are registered trademarks of the National Fire Protection Association, Quincy, MA.

The National Fire Protection Association did not produce, review or approve this publication and assumes no responsibility for the application or use of any NEC related material or product set out herein.

Do not duplicate any part of this publication without the permission of a member of the Industry Affairs Group of Thomas & Betts.



**Thomas&Betts**  
A Member of the ABB Group