Thomas & Betts ANALYSIS OF NEC ®

2017 Code Changes: Article Section 690.56(C) Buildings with Rapid Shutdown Section 690.56(C) Buildings with Rapid Shutdown



© 2017 Thomas & Betts. Specifications are subject to change without notice.

Section 690.56(C) Buildings with Rapid Shutdown

Section 690.56(C) Buildings with Rapid Shutdown

(C) Buildings with Rapid Shutdown. Buildings with PV systems shall have permanent as described in 690.56(C)(1) through (C)(3).

(1) Rapid Shutdown Type. The type of PV system rapid shutdown shall be labeled as described in 690.56(C)(1)(a) or (1)(b):

(a) For PV systems that shut down the array and conductors leaving the array:

SOLAR PV SYSTEM IS EQUIPPED WITH RAPID SHUTDOWN. TURN RAPID SHUTDOWN SWITCH TO THE "OFF" POSITION TO SHUT DOWN PV SYSTEM AND REDUCE SHOCK HAZARD IN ARRAY.

The title "SOLAR PV SYSTEM IS EQUIPPED WITH RAPID SHUTDOWN" shall utilize capitalized characters with a minimum height of 9.5 mm (3/8 in.) in black on yellow background, and the remaining characters shall be capitalized with a minimum height of 4.8 mm (3/16 in.) in black on white background. [See Figure 690.56(C)(1)(a).]

(b) For PV systems that only shut down conductors leaving the array:

SOLAR PV SYSTEM IS EQUIPPED WITH RAPID SHUTDOWN TURN RAPID SHUTDOWN SWITCH TO THE "OFF" POSITION TO SHUT DOWN CONDUCTORS OUTSIDE THE ARRAY. CONDUCTORS IN ARRAY REMAIN ENERGIZED IN SUNLIGHT.

The title "SOLAR PV SYSTEM IS EQUIPPED WITH RAPID SHUTDOWN" shall utilize capitalized characters with a minimum height of 9.5 mm (3/8 in.) in white on red background, and the remaining characters shall be capitalized with a minimum height of 4.8 mm (3/16 in.) in black on white background. [See Figure 690.56(C)(1)(b).]

The labels in 690.56(C)(1)(a) and (b) shall include a simple diagram of a building with a roof. The diagram shall have sections in red to signify sections of the PV

system that are not shut down when the rapid shutdown switch is operated.

The rapid shutdown label in 690.56(C)(1) shall be located on or no more than 1 m (3 ft) from the service disconnecting means to which the PV systems are connected and shall indicate the location of all identified rapid shutdown switches if not at the same location.

(2) Buildings with More Than One Rapid Shutdown Type. For buildings that have PV systems with both rapid shutdown types or a PV system with a rapid shutdown type and a PV system with no rapid shutdown, a detailed plan view diagram of the roof shall be provided showing each different PV system and a dotted line around areas that remain energized after the rapid shutdown switch is operated.

(3) **Rapid Shutdown Switch.** A rapid shutdown switch shall have a label located on or no more than 1 m (3 ft) from the switch that includes the following wording:

RAPID SHUTDOWN SWITCH FOR SOLAR PV SYSTEM

The label shall be reflective, with all letters capitalized and having a minimum height of 9.5 mm (3/8 in.), in white on red background.

Analysis of the Change

Building labeling requirements for Rapid Shutdown were expanded upon with revised markings and additional labeling. The revision requires that any building with a rapid-shutdown PV system has a plaque to indicate to first responders that rapid-shutdown is provided. It also harmonizes the location with the requirements for general plaques for off grid systems (690.56 (A)), or utility interactive systems (690.56(B)). Lastly, if the rapid shutdown device is not the service disconnecting means or adjacent to it, the plaque is required to identify the initiator location.

Products

ABB's Rapid Shutdown Products







© 2017 Thomas & Betts. Specifications are subject to change without notice.

Contact Us

If you have any questions or require interpretation assistance, please contact the following:

David Kendall 1-800-888-0211 Ext. 8879 Greg Steinman 1-800-888-0211 Ext. 5719 Jean Blanc 1-800-888-0211 Ext. 5670

Thomas & Betts Corporation 8155 T&B Blvd. Memphis, TN 38125 www.tnb.com

Disclaimer: This is not intended to be an iteration of all the changes, but a reference of a change that may affect the Thomas & Betts, ABB & Baldor product lines. For a more in-depth document, please contact the International Association of Electrical Inspectors at www.iaei.org.

Material taken from the National Electrical Code is reprinted with permission from NFPA 70®-2017, National Electrical Code®, Copyright © 2016, National Fire Protection Association, Quincy, MA. This material is not the official position of the NFPA on the referenced subject, which is represented only by the standard in its entirety.

National Electrical Code[®] and NEC[®] are registered trademarks of the National Fire Protection Association, Quincy, MA.

The National Fire Protection Association did not produce, review or approve this publication and assumes no responsibility for the application or use of any NEC related material or product set out herein.

Do not duplicate any part of this publication without the permission of a member of the Industry Affairs Group of Thomas & Betts.



