# HOMAC\*

### **HM 52 (1/2 PINT)**

## OXIDE INHIBITING COMPOUND

GID# 7TAA265950R0002

For Full Tension Splices Only. Mfg. Part # 195-23390



#### **Directions:**

- 1) To open sealed spout, cut off approximately 3/8" from end.
- 2) Thoroughly clean all conductors and conductor contact surfaces with a stainless steel wire brush
- Apply a generous coating of compound to all prepared surfaces.
- 4) Remove all excess compound from parts after installation.

CAUTION: \_\_\_\_ 
Do not wire brush plated surfaces of connectors.



#### PRECAUTIONARY STATEMENT:

**Prevention:** Observe good industrial hygiene practices.

Response: Wash hands after handling.

**Storage:** Store away from incompatible materials.

**Disposal:** Dispose of waste and residues in accordance

with local authority requirements.

For product information call 800-816-7809 For emergencies only. Call INFOTRAC: +1 800-535-5053

> Safety Data Sheet Number SDS-00040

#### **Limited Warranty Applies.**

Refer to: tnb.abb.com/ecpwarranty for full warranty terms.

### **Supplier Identification:**

ABB Installation Products Inc. 860 Ridge Lake Boulevard Memphis, Tennessee, 38120 electrification.us.abb.com

#### **Country of Origin: United States**

© 2024 ABB Installation Products Inc. and/or its related companies. All Rights Reserved.

