


FOR INSTALLING STA-KON® NON-INSULATED  
AB & C FLAGS 22-10 AWG AND NON-INSULATED  
TERMINALS, DISCONNECTS, AND SPLICES  
22-18, 12-10 AWG ON COPPER WIRE



**CAUTION:** HANDLES NON-INSULATING,  
DO NOT CRIMP ENERGIZED WIRES

<b>GENERAL NOTES</b>		<b>STAKON®</b> <small>www.tnb.com</small>		<b>Thomas &amp; Betts</b> A Member of the ABB Group	
1. ALL DIMENSIONS ARE FOR REFERENCE ONLY. 2. DIMENSIONS IN BRACKETS [ ] ARE IN METRIC UNITS.					
<b>REVISIONS</b>		DESCRIPTION <b>ERG4004 COMFORT CRIMP® COMPRESSION TOOL WITH SHURE STAKE® MECHANISM</b>			
1 SEE ERN (2016820) FOR APPROVAL SIGNATURES & RELEASE DATE. PROJECT NO: 029M000853		ORIGINAL PROJECT NO / ( ERN NO )  TD55632 / ( 2010868 )	SHEET NO:  1 OF 1	REV. NO:  1	DRAWING NO:  WSD-000498

THIS DRAWING IS INTENDED FOR DESCRIPTIVE PURPOSES ONLY. AND THE RIGHT IS RESERVED TO DEViate FROM ANY OF THE DETAILS SHOWN HEREON.  
COPYRIGHT THOMAS & BETTS CORPORATION. ALL RIGHTS RESERVED. PROPRIETARY AND CONFIDENTIAL.